



Government of Karnataka



Office of the District Fire Officer, Karnataka State Fire and Emergency Services,
Mysuru District, Saraswathipuram, Mysuru-09.

Tel : 0821-2493101

Email : dfomyuru.ksfes[at]ka.gov.in

Mob : 9480823660

No: School/FSR-56/DFO/MY/2024-25.

Date:- 19-02-2025.

To,

The Secretary

Geethanjali Education Society®

#27, Sri Lalitha Sonar Street,

Chamaraja Mohalla, Mysuru-570004.

Sub : Issued the 'Fire safety recommendation' to existing building of "Geethanjali Education Society®" at # 27, Sri Lalitha Sonar Street, Chamaraja Mohalla, Mysuru-570004.

Ref : 1. Your request letter, dated: 23-01-2025.

2.C.No:80/School/FSR/SFS/MY/2025(08), dated: 07-02-2025.

><<>*@*<<><

With reference to the subject above cited, the premises of "Geethanjali Education Society®" building at #27, Sri Lalitha Sonar Street, Chamaraja Mohalla, Mysuru-570004. was inspected by Fire Station Officer Saraswathipuram, On 04-02-2025 with respect to Fire prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-B

"Group B Educational Buildings"

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings sub division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

Part-A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Secretary Geethanjali Education Society ® #27, Sri Lalitha Sonar Street, Chamaraja Mohalla, Mysuru-570004.
02	Name and Address of the premises.	:	M/S Geethanjali Education Society ® Srirampura 2 nd Stage, BEML Layout, Mysuru.
03	Name and address of the Building owner	:	The Secretary Geethanjali Education Society ® #27, Sri Lalitha Sonar Street, Chamaraja Mohalla, Mysuru-570004.
04	Number of buildings	:	01 Building.
05	Number of floors	:	Ground Floor And 01 Upper floor.
06	Floor-wise details of occupancy:-		
	Ground floor	:	08 Class rooms, Laboratory, Library, Office Room, Principal Room, Management Office, Staff room, Store room & 02 Wash rooms.



	1 st floor	:	08 Class rooms, Laboratory, Library, Office Room, Principal Room, Management Office, Staff room, Store room & 02 Wash rooms.
07	Height of the building	:	06.45 Mtrs.
08	Site area	:	9391.05 Sq. Mtrs.
09.	Built-up area of each floor:-	:	Ground floor:- 1628.81 Sq. Mtrs. 1 st floor:- 1628.81 Sq. Mtrs.
10.	Total built-up area	:	3257.62 Sq. Mtrs.
11.	Surrounding properties:-		
	North (Front)	:	06 Mtrs. Wide J.S.S. School Road.
	South (Rear)	:	Private Property.
	East (Side)	:	SY.NO.81.
	West (Side)	:	C.A Site(Reserved K.S.R.T.C.)
12.	Set-back area available around the building :-		
	North (Front)	:	04.90 Mtrs.
	South (Rear)	:	04.80 Mtrs.
	East (Side)	:	05.00 Mtrs.
	West (Side)	:	55.78 Mtrs.
	Allowed setback (open space) should be maintained free from further obstruction / construction.		

Part-B. On inspection of this Educational premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	This premise is abutting 06.00 mtrs. width road towards Northern side. This Road Is hardened to carry the weight of 45.000 kgs.		Adequate.
02.	No. of entrances	02 Entrances.		Adequate.
03.	Width of Entry/Exit	01 Entrance. - 07.20 Mtrs & Another 5.00 Mtrs Width.		Adequate.
04.	No. of staircases available	Nos. of staircases	01 No.	Adequate.
		Width of staircases	01.25 Mtrs.	
		Width of treads	30 CM	
		Height of risers	15 CM	



		Nos. of riser per flight	10 No's sp	
		Height of handrails	01.10 Mtrs.	
		Head room clearance	02.20 Mtrs.	
05.	No, Lifts and capacity	Nos. of lifts	01	Adequate.
		Capacity of lifts	900 kg (15 Persons)	
06.	Diesel generators.	Not provided.		Not Compiled. Recommended One diesel generator Of 15 KVA Capacities has been provided to supply alternative power supply.
07.	Portable Fire Extinguisher.	Not provided.		A. One water mist extinguishers of 9 ltrs capacity should kept near each staircase landing. B. One mechanical foam extinguishers of 9 ltrs capacity & one ABC type extinguishers of 6 kgs capacity should be provided near diesel generator. C. One CO2 type fire extinguisher, of 4.5 kgs capacity should be provided near each electrical panel board & electrical room. D. One ABC type fire extinguisher of 6 kgs capacity should be located as to be available within 15 mtrs. radius. All the extinguishers suggested above should be with BIS markings and should be located at an easily accessible position without



			obstructing the normal passage and maintained periodically.
08.	First aid Hose reel hose.	Not provided.	Not Compiled. Hose Reel Hose near the staircase (One hose reel hose system for every 1000 Sq. mtrs. buildup area). The hose reel hose of min 19 mm size and 100 mm internal diameter made up of G.I 'C' class pipe and of adequate length to reach the farthest point of each floor and shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing of each building/block/ wing/ tower.
09.	Terrace tank over respective tower terrace.	Not provided.	Not Compiled. Recommended To provide 01 no.Overhead tank at building, of 10,000 ltrs Capacities.
10.	Pump At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	Not provided.	Not Compiled. Hose reel hose system should be connected to a booster pump of 450 LPM or of 5 HP capacities. (Further the system should be connected to an alternative source of power supply)
11.	Escape routes.	Not marked.	Not Compiled. Directions in which the inmate's should have to move in the event of any emergency have to be indicated in the corridor/passage as a guide during evacuation. These marking should be in luminous paint.
12.	Fire order. (Fire Safety plans)	Not displayed.	Not Compiled. A notice board indicating the



			action to be taken by the employees in case of any emergency should be displayed along with the telephone number of Saraswathipuram Fire Station, 0821-2540970 & 101 and the telephone number of nearest ambulance service & Police station.
13.	No Smoking board.	Not displayed.	Not Compiled. As per Sec-4 of COPTA a board with words NO SMOKING AREA shall be written in English & Kannada both languages shall be prominently displayed at inside the entry / exit of the each floor.
14.	Training in Fire fighting .	Not imparted.	Not Compiled. At-least 40% of Teaching and non teaching staff should be got trained in fire fighting at R.A Mundkur Fire & Emergency Services Academy, Bannerghatta Road, Bangalore or Regional Training Center.
15.	Fire Siren.	Not installed.	Not Compiled. A Fire Siren shall be installed in the Premises to inform the inmates in case of a fire emergency and evacuate the area.
16.	Nominate one Fire Nodal Officer.	Not imparted.	Not Compiled. A Fire nodal officer shall be nominated either from teaching or non teaching staff.

Fire precautionary measures.

- A. Explosive and flammable material should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises.
- B. Accumulation of combustile waste in and around the premises should be avoided.




- C. The exit ways shall be always kept clear without any obstruction.
- D. Liquefied petroleum gas should not be stored in the building except in the Kitchen (Provided for Mid-Day Meal Preparation)
- E. The doors shall not be kept locked / latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- As per Hon'ble supreme court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year by conducting Fire Safety drills with co-ordinate with fire service department.

Under the above circumstance the Karnataka Fire & Emergency Service Department is issuing 'Fire Safety Recommendation' to "Geethanjali Education Society®" building at #27, Sri Lalitha Sonar Street, Chamaraja Mohalla, Mysuru-570004, subject to condition and compliance of the above recommendations in within 3 months and compliance to the undersigned.

This Fire Safety Recommendation is valid for only one year from the date of issue and it is renewable".

♣ All requirements recommended above are as per National Building code-2016 Part-4 Clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.



Yours faithfully,

 District Fire Officer
 Mysuru District, Saraswathipuram
 Karnataka State Fire & Emergency Services
 Mysuru 570 009

19/02/25

Copy with compliments: Submitted to
 the Director General of Police and Director General,
 Karnataka State Fire and Emergency Services, Bengaluru-42.

Copy To,
 Fire Station Officer, Saraswathipuram Fire Station,
 Saraswathipuram, Mysuru-09.



Office of The District Fire Officer

Karnataka Fire & Emergency Services, Bannimantap, Mysuru-570015

E-mail:dfobannimantap.ksfes@ka.gov.in

Tele: 0821-2492101

No.07/CC/DFO/BFS/MYS/2025-26

Date:-21-02-2026

To,

The Secretary

Geethanjali Education Society ®

#27, Sri Lalitha Sonar Street,

Chamaraja Mohalla, Mysuru-04.

Sub: Issue of “Renewal Fire Safety Compliance certificate” with respect to fire prevention, Fighting and evacuation measures maintained at, **Geethanjali International Global School**” Building at CA-7, BEML Layout, Srirampura 2nd Stage, Mysuru.

Ref: 1 FSR No-56/Rec/DFO/MY/2024-25 Date:-19-02-2025.

2. Your request letter dated: 21-02-2026.

3 No.07/CC/DFO/BFS/MYS/2025-26 Date:-21-02-2026.

With reference to the above cited subject, as per reference (1) Fire safety recommendation certificate was issued to the premises of “**Geethanjali International Global School**” Building at CA-7, BEML Layout, Srirampura 2nd Stage, Mysuru. With a condition to fulfill the recommendations and compliance the same within 03 months.

Now as per reference (2) the School/College management submitted the requisition for fire safety compliance certificate.

In this regard as per reference (3) The Premises was inspected by me on **21-02-2026** & Submitted the report fulfilled the firefighting systems and found the firefighting systems are in good working condition during inspection and recommended to issue ‘Renewal fire safety compliance certificate.

Under the above circumstances the Karnataka fire & emergency services department is issuing the “**Renewal Fire Safety Compliance certificate**” to “**Geethanjali International Global School**” Building at CA-7, BEML Layout, Srirampura 2nd Stage, Mysuru. Subject to proper maintenance of firefighting installations in good working conditions **This Renewal Fire Safety Compliance Certificate valid for only Two year from the date of issue and is renewable.**

Copy to, with due respect,

The Director General of Police

and Director General,

Karnataka Fire And Emergency Service

Bangalore-560042.


District Fire Officer

Karnataka State Fire & Emergency Services
Bannimantap Fire Station
Mysore-570015

